

MEMORANDUM

PA 80-A
5-43

REFER		NOTED	
TO	DATE	BY	DATE
RETURN TO		FILE	

K-127 13
J. J. J.

TO: File
 FROM: D. Herbatman
 DATE: April 27, 1971
 SUBJECT: INSPECTION BY NEW YORK STATE LABOR DEPARTMENT DIVISION OF INDUSTRIAL HYGIENE - 4/20/71
 REFERENCE:
 COPY TO: R.M. Monti, P. Falvey, A. Raiolo

On April 20, 1971, representatives of the Division of Industrial Hygiene, New York State Department of Labor, visited the site for the purpose of observing the spray-on fire proofing operation conducted by Mario and DiBuono.

Present at this inspection were Mr. J. Baliss, Chief of the Division of Industrial Hygiene, Mr. M. Scheinbaum, Senior Industrial Hygiene Engineer, Mrs. Shebe, a lawyer presently assigned to work with the Industrial Hygiene Division and D. Herbatman World Trade Safety Supervisor.

Mr. T. Guarino of Mario and DiBuono accompanied us on the inspection which covered the spray-on operation in Tower A at the 80th floor and operations in the Custom and Northeast Plaza Buildings.

Mr. Scheinbaum took air samples at a number of points while observing operations on the 80th floor of Tower A. The group was generally impressed with the tight canvas protection, rapid clean-up and use of personal protective equipment, including filter type respirators.

As discussed at lunch after the inspection, the primary purpose of this group is to re-evaluate the present restrictions on the use of spray-on fireproofing material containing asbestos. New standards are being established which will make it extremely difficult to use this material throughout New York State unless a much higher level of protection for workers engaged in applying the asbestos material as well as other workmen in the vicinity of this work, is supplied.

A tentative new standard will relate to fibers per milliliter rather than total dust count. This may also involve other mineral type fiber material after the initial restriction on the asbestos type material.

Hearings will be scheduled in the near future to determine whether the proposed revisions are acceptable and if so when they will be adopted.

[Signature]
 Donald Herbatman
 Safety Supervisor
 World Trade Center

DH/bp

